
 6/9/08
Allen Family Foods Inc.
126 North Shipley Street
Seaford, De. 19973

From the desk of
Tom Brinson

Corporate Environmental Manager



To: Glenn Davis

Subject: Harbeson Storm Water

Date: June 3, 2008

Glenn,

This letter is to follow up our phone conversation this morning, concerning the power outage at the Harbeson Processing Plant on May 31, 2008. A significant storm occurred during the afternoon of May 31, 2008 in the Harbeson, Delaware area consisting of severe lightning, strong winds and torrential rain. A sub-station in Milton, Delaware was struck by lightning which resulted in a power failure that lasted approximately 4 hours. A total of 1.1 inches of rainfall were recorded.

At 1746 hours Allen's security notified Michael Sausé that power was out at the Allen's plant and the surrounding area. Michael Sausé notified Tom Paine of the power outage and he proceeded to the plant and arrived at approximately 1800 hours. To protect the integrity of the equipment from a spike during power restoration, the first thing Tom Paine did was perform the emergency shutdown of all equipment that was on line at the time of the power outage. This took approximately one hour.

At approximately 1900 hours, the rain, winds and lightning had subsided and Tom Paine performed an inspection of the plant. Mr. Paine noted no discharge at Storm Water Station 002; he did note a slight discharge from Storm Water Station 003. However, due

to this limited trickle, Mr. Paine was unable to get a sample of sufficient quantity that would be needed for analyses.

I was notified on June 2, 2008 of the outage, I then notified Amber Moore of DNREC by telephone at 1516 hours that day by leaving a voicemail. I received a call from Amber Moore on June 3, 2008 at 0747 hours and informed her on the specifics of the power outage. Should you have any questions, please feel free to contact me.

Respectfully Submitted,



Tom Brinson

Cc: Amber Moore
File